
Building Information

Animal Bioscience

System Information

System Type: Variable Air Volume with Hot Water Reheat

Occupied Space Temperature Control: Individual/Zone VAV Control

Does this Building Offer Simultaneous Heating and Cooling?: Yes

Occupied Hours

Monday-Friday: 7am -6pm

Saturday: 8am -6pm

Sunday: 8am -6pm

Heating

Is the building Heated?: Yes

Heating Minimum & Maximum: 65°-72°F

Cooling

Is the Building Cooled?: Yes

Cooling Minimum & Maximum Guidelines: 70°-80°F

Date on Which Cooling is Enabled: N/A

Date on Which Cooling is Disabled: N/A

Switchover Controls

Type of Switchover Controls in Place: Automatic

Switchover Point: No Seasonal Changes